

BEDMINSTER TOWNSHIP PUBLIC SCHOOL DISTRICT

234 Somerville Road
Bedminster, NJ 07921
Telephone (908) 234-0768 Fax (908) 234-2318
www.bedminsterschool.org

March 27, 2025

Dear Bedminster Township School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the Bedminster Township School tested our schools' drinking water for lead on January 2, 2025.

In accordance with the Department of Education regulations, Bedminster Township School does not need to implement immediate remedial measures for any drinking water outlet since results are not greater than the action level of 15 µg/l (parts per billion [ppb]).

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for the building within the Bedminster Township School. Through this effort, we identified and tested the drinking water and food preparation outlets. Of the samples taken, all tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]), except storage unit 274. This is not an open water source for drinking. Storage unit 274 was never flushed and this is not an open drinking supply unit. It is marked with signage to not use for drinking purposes.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning, can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and are also available on our website at www.bedminsterschool.org. For more information about water quality in our schools, contact the School Business Administrator at sba@bedminsterschool.org.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your healthcare provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Jennifer Giordano, Ed.D.
Superintendent



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Bedminster Elementary School
234 Somerville Road
Bedminster, NJ 07921

Project ID : Bedminster Elementary School, 234 Somerville Road, Bedminster NJ 07921
PAS Project ID : P24-13318

Matrix : Drinking Water
Report Date : 1/2/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-13318-01	Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:40	12/23/24 15:17
P24-13318-02	WC-CH-1 (POE)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:41	12/23/24 15:21
P24-13318-03	KC-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:43	12/23/24 15:45
P24-13318-04	KC-2	Lead	0.990 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:44	12/23/24 15:50
P24-13318-05	KC-3	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:45	12/23/24 15:54
P24-13318-06	KFP-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:47	12/23/24 15:58
P24-13318-07	KFP-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:48	12/23/24 16:02
P24-13318-08	KC-4	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:48	12/23/24 16:06
P24-13318-09	TL-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:51	12/23/24 16:10
P24-13318-10	247-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:52	12/23/24 16:14
P24-13318-11	242-DW	Lead	0.990 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:53	12/23/24 16:26
P24-13318-12	241-DW-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:55	12/23/24 16:30
P24-13318-13	241-DW-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:56	12/23/24 16:34
P24-13318-14	NS-DW-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:58	12/23/24 16:38
P24-13318-15	NS-DW-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 05:59	12/23/24 16:42
P24-13318-16	213-DW-NB	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:01	12/23/24 16:46
P24-13318-17	263-DW-1	Lead	5.33	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:03	12/23/24 16:50
P24-13318-18	263-DW-2	Lead	1.47 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:04	12/23/24 16:54
P24-13318-19	269-DW-1	Lead	1.23 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:05	12/23/24 16:58
P24-13318-20	269-DW-2	Lead	6.05	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:05	12/23/24 17:10
P24-13318-21	262-DW-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:11	12/23/24 17:14
P24-13318-22	262-DW-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:12	12/23/24 17:18
P24-13318-23	271-DW-1	Lead	5.57	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:15	12/23/24 17:22
P24-13318-24	268-DW-1	Lead	2.92	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:16	12/23/24 17:26
P24-13318-25	273-DW	Lead	0.990 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:17	12/23/24 17:30
P24-13318-26	270-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:18	12/23/24 17:34
P24-13318-27	277-DW	Lead	1.47 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:20	12/23/24 18:02
P24-13318-28	272-DW	Lead	1.71 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:21	12/23/24 18:18
P24-13318-29	279-DW	Lead	0.990 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:22	12/23/24 18:22
P24-13318-30	274-DW	Lead	29.0	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	12/20/24 06:22	12/23/24 19:11
P24-13318-31	276-DW	Lead	6.29	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:23	12/23/24 19:15
P24-13318-32	278-DW	Lead	1.23 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:24	12/23/24 19:19
P24-13318-33	280-DW	Lead	5.01	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:24	12/23/24 18:05
P24-13318-34	289-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:25	12/23/24 18:09
P24-13318-35	291-DW	Lead	4.42	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:26	12/23/24 18:14
P24-13318-36	128-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:30	12/23/24 18:18
P24-13318-37	131-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:31	12/23/24 18:32
P24-13318-38	126-DW	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:32	12/23/24 18:36
P24-13318-39	129-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:33	12/23/24 18:40
P24-13318-40	122-DW	Lead	4.22	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:35	12/23/24 18:45
P24-13318-41	116-DW	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:37	12/23/24 18:49
P24-13318-42	114-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:38	12/23/24 18:54
P24-13318-43	115-DW	Lead	1.45 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:40	12/23/24 18:58
P24-13318-44	112A-DW	Lead	5.80	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:41	12/23/24 19:03
P24-13318-45	113-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:44	12/23/24 19:07
P24-13318-46	110-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:46	12/23/24 19:21
P24-13318-47	111-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:46	12/23/24 19:25

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

CERTIFICATE OF ANALYSIS

Customer : Bedminster Elementary School
234 Somerville Road
Bedminster, NJ 07921

Project ID : Bedminster Elementary School, 234 Somerville Road, Bedminster NJ 07921
PAS Project ID : P24-13318

Matrix : Drinking Water
Report Date : 1/2/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-13318-48	108-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:47	12/23/24 19:30
P24-13318-49	109-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:48	12/23/24 19:48
P24-13318-50	106-DW	Lead	1.45 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:49	12/23/24 19:53
P24-13318-51	105-DW	Lead	2.04	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:50	12/23/24 19:57
P24-13318-52	104-DW	Lead	1.84 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:50	12/23/24 20:11
P24-13318-53	103-DW	Lead	1.45 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:51	12/23/24 20:15
P24-13318-54	102-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:52	12/23/24 20:20
P24-13318-55	101-DW	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:53	12/24/24 13:53
P24-13318-56	337-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:56	12/24/24 14:20
P24-13318-57	301-DW	Lead	3.79	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:56	12/24/24 14:24
P24-13318-58	336-DW	Lead	12.8	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:57	12/24/24 14:29
P24-13318-59	335-DW	Lead	8.61	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:58	12/24/24 14:33
P24-13318-60	306-DW	Lead	3.39	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:58	12/24/24 14:37
P24-13318-61	334-DW	Lead	2.39	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:59	12/24/24 14:42
P24-13318-62	333-DW	Lead	2.99	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 06:59	12/24/24 14:46
P24-13318-63	307-DW	Lead	1.39 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:00	12/24/24 14:51
P24-13318-64	332-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:00	12/24/24 15:05
P24-13318-65	308-DW	Lead	8.21	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:01	12/24/24 15:09
P24-13318-66	331-DW	Lead	1.79 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:01	12/24/24 15:14
P24-13318-67	309-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:02	12/24/24 15:18
P24-13318-68	330-DW	Lead	8.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:03	12/24/24 15:23
P24-13318-69	310-DW	Lead	3.64	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:03	12/23/24 19:23
P24-13318-70	311-DW	Lead	2.19	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:04	12/23/24 19:27
P24-13318-71	312-DW	Lead	1.95 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:04	12/23/24 19:31
P24-13318-72	315-DW	Lead	2.19	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:05	12/23/24 19:35
P24-13318-73	323-DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:06	12/23/24 19:47
P24-13318-74	322-DW	Lead	1.47 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:06	12/23/24 19:51
P24-13318-75	WC 3RD FL-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:09	12/23/24 19:55
P24-13318-76	WC 3RD FL-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:09	12/23/24 19:59
P24-13318-77	WC 3RD FL-3	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:10	12/23/24 20:03
P24-13318-78	WC 3RD FL-4	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:10	12/23/24 20:07
P24-13318-79	WC 2ND FL-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:12	12/23/24 20:11
P24-13318-80	WC 2ND FL-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:12	12/23/24 20:16
P24-13318-81	WC 2ND FL-3	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:13	12/23/24 20:20
P24-13318-82	WC 2ND FL-4	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:13	12/24/24 15:27
P24-13318-83	WC 1ST FL-1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:16	12/24/24 15:32
P24-13318-84	WC 1ST FL-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:16	12/24/24 15:37
P24-13318-85	WC 1ST FL-3	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:16	12/24/24 15:41
P24-13318-86	WC 1ST FL-4	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:17	12/24/24 15:55
P24-13318-87	WC-CH-2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/20/24 07:20	12/24/24 15:59

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: **Bedminster Elementary School**
 Address: **234 Somerville Road**
Bedminster, NJ 07921
 Phone: **908-234-0768 Ext. 306 908-234-1489 Ed Billings**

School Name: **Bedminster Elementary School**
 School Address: **234 Somerville Road, Bedminster, NJ 07921**
 Sampled By: *[Signature]*
 Print Name: **Eric Munnikus**
 RESULTS TO: **edbillings@bedminsterschool.org**

Sample ID Location	Date: 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Qlors or Plastic	Analysis	LAB ID
FIELD BLANK	05:40 12-20-24	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-01
WC-CH-1 (POE)	05:41 12-20-24	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-02
KC-1	05:43	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-03
KC-2	05:44	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-04
KC-3	05:45	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-05
KFP-1	05:47	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-06
KFP-2	05:48	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-07
KC-4	05:48	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-08
TL-DW	05:51	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-09
247-DW	05:52	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-10
242-DW	05:53	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-11
241-DW-1	05:55	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-12
241-DW-2	05:56	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-13
NS-DW-1	05:58	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-14
NS-DW-2	05:59	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-15

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Page 1 of 6

Deliverables:

Date/Time Preserved with HNO₃: **PRESERVED**

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = HNO3, 4 = HNO2, 5 = Other

	Print Name:	Signature:	Initials	Date + Time
Relinquished:	<i>Eric Munnikus</i>	<i>[Signature]</i>	YAL	12-20-2024
Received:	<i>ZAINE FINLEY</i>	<i>[Signature]</i>	YAL	11:20
Relinquished:				
Received:				
Relinquished:				
Received:				



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: Bedminster Elementary School
 Address: 234 Somerville Road
Bedminster, NJ 07921
 Phone: 908-234-0768 Ext. 306 908-234-1489 Ed Billings

School Name: Bedminster Elementary School
 School Address: 234 Somerville Road, Bedminster, NJ 07921
 Sampled By: [Signature]
 Print Name: Eric Mannikw
 RESULTS TO: edbillings@bedminsterschool.org

Sample ID Location	Date: 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Push Sample	Filter Process	# Containers	Glass or Plastic	Analysis	LAB ID
213-DW-NB	06:01	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-16
263-DW-1	06:03	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-17
263-DW-2	06:04	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-18
269-DW-1	06:05	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-19
269-DW-2	06:05	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-20
269-DW-1 262-DW1	06:11	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-21
269-DW-2 262-DW2	06:12	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-22
271-DW-1	06:15	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-23
268-DW-1	06:16	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-24
273-DW	06:17	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-25
270-DW	06:18	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-26
277-DW	06:20	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-27
272-DW	06:21	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-28
279-DW	06:22	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-29
274-DW	06:22	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-30

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Date/Time Preserved with HNO₃:

PREPRESERVED

Page 2 of 6

Deliverables:

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------	--------------------------	--------------------------	--------------------------

MATRIX CODEs: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATI
 USE CODEs: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = HNO3, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Eric Mannikw	[Signature]	YAL	12-20-2024
Received:	ZAYNE FINEV	[Signature]	YAL	11:20
Relinquished:				
Received:				
Relinquished:				
Received:				



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: **Bedminster Elementary School**
 Address: **234 Somerville Road**
Bedminster, NJ 07921
 Phone: **908-234-0768 Ext. 306 908-234-1489 Ed Billings**

School Name: **Bedminster Elementary School**
 School Address: **234 Somerville Road, Bedminster, NJ 07921**
 Sampled By: *[Signature]*
 Print Name: **Eric Mannikas**
 RESULTS TO: **edbillings@bedminsterschool.org**

Sample ID Location	Date: 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Filter Present	# Containers	Class or Plastic	Analysis	LAB ID
276-DW	06:23	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-31
278-DW	06:24	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-32
280-DW	06:24	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-33
289-DW	06:25	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-34
291-DW	06:26	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-35
128-DW	06:30	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-36
131-DW	06:31	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-37
126-DW	06:32	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-38
129-DW	06:33	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-39
122-DW	06:35	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-40
116-DW	06:37	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-41
114-DW	06:38	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-42
115-DW	06:40	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-43
112A-DW	06:41	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-44
113-DW	06:44	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-45

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Date/Time Preserved with HNO₃

PREPRESERVED

Page 3 of 6

Deliverables:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = HNO3, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	<i>Eric Mannikas</i>	<i>[Signature]</i>	YAL	12-20-2024
Received:	ZAYNE FENLEY	<i>[Signature]</i>	YAL	11:20
Relinquished:				
Received:				
Relinquished:				
Received:				



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: Bedminster Elementary School
 Address: 234 Somerville Road
Bedminster, NJ 07921
 Phone: 908-234-0768 Ext. 306 908-234-1489 Ed Billings

School Name: Bedminster Elementary School
 School Address: 234 Somerville Road, Bedminster, NJ 07921
 Sampled By: *[Signature]*
 Print Name: *Eric Mannikus*
 RESULTS TO: edbillings@bedminsterschool.org

Sample ID Location	Date: 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
110-DW	06:46	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-46
111-DW	06:46	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-47
108-DW	06:47	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-48
109-DW	06:48	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-49
106-DW	06:49	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-50
105-DW	06:50	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-51
104-DW	06:50	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-52
103-DW	06:51	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-53
102-DW	06:52	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-54
101-DW	06:53	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-55
337-DW	06:56	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-56
301-DW	06:56	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-57
336-DW	06:57	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-58
335-DW	06:58	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-59
306-DW	06:58	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-60

SAMPLES REC'D PRESERVED WITH HNO₃

Page 4 of 6

Deliverables:	PDF Std. <input checked="" type="checkbox"/>	PDF Reduce <input type="checkbox"/>	PDF Full <input type="checkbox"/>	EDD <input type="checkbox"/>
---------------	----------------------------------------------	-------------------------------------	-----------------------------------	------------------------------

Preserved with HNO₃: **PREPRESERVED**

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Receiver	Date + Time
Relinquished:	<i>Eric Mannikus</i>	<i>[Signature]</i>	YAL	12-20-2024
Received:	ZALINE FEAREY	<i>[Signature]</i>	YAL	11:20
Relinquished:				
Received:				
Relinquished:				
Received:				



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: Bedminster Elementary School
 Address: 234 Somerville Road
Bedminster, NJ 07921
 Phone: 908-234-0768 Ext. 306 908-234-1489 Ed Billings

School Name: Bedminster Elementary School
 School Address: 234 Somerville Road, Bedminster, NJ 07921
 Sampled By: [Signature]
 Print Name: Ed Billings
 RESULTS TO: edbillings@bedminsterschool.org

Sample ID Location	Date: 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Class or Plastic	Analysis	LAB ID
334-DW	06:59	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-61
333-DW	06:59	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-62
307-DW	07:00	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-63
332-DW	07:00	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-64
308-DW	07:01	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-65
331-DW	07:01	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-66
309-DW	07:02	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-67
330-DW	07:03	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-68
310-DW	07:03	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-69
311-DW	07:04	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-70
312-DW	07:04	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-71
315-DW	07:05	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-72
323-DW	07:06	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-73
322-DW	07:06	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-74
WC 3RD FL-1	07:09	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-75

SAMPLES REC'D PRESERVED WITH HNO₃

Deliverables: PDF Std. PDF Reduce PDF Full EDD

Date/Time Preserved with HNO₃: PREPRESERVED

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Analysis	Date + Time
Relinquished:	<u>Eric Mannikus</u>	<u>[Signature]</u>	<u>YAL</u>	<u>12-20-2024</u>
Received:	<u>JAYNE FENLEY</u>	<u>[Signature]</u>	<u>YAL</u>	<u>11:20</u>
Relinquished:				
Received:				
Relinquished:				
Received:				



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: **Bedminster Elementary School**
 Address: **234 Somerville Road**
Bedminster, NJ 07921
 Phone: **908-234-0768 Ext. 306 908-234-1489 Ed Billings**

School Name: **Bedminster Elementary School**
 School Address: **234 Somerville Road, Bedminster, NJ 07921**
 Sampled By: *[Signature]*
 Print Name: **Eric Mannikus**
 RESULTS TO: **gdbillings@bedminsterschool.org**

Sample ID Location	Date 12/20/24 Time Sampled	Matrix Code	Grab or Comp	Plumb Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
WC 3RD FL-2	07:09	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-76
WC 3RD FL-3	07:10	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-77
WC 3RD FL-4	07:10	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-78
WC 2ND FL-1	07:12	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-79
WC 2ND FL-2	07:12	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-80
WC 2ND FL-3	07:13	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-81
WC 2ND FL-4	07:13	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-82
WC 1ST FL-1	07:16	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-83
WC 1ST FL-2	07:16	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-84
WC-1ST FL-3	07:14	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-85
WC 1ST FL-4	07:17	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-86
WC-CH-2	07:20	DW	Grab	N		1	250 ml Plastic	Lead	P24-13318-87
									P24-
									P24-
									P24-

SAMPLES RECD PRESERVED WITH HNO₃

Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO₃: *PRESERVED*

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = HNO3, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	<i>Eric Mannikus</i>	<i>[Signature]</i>	YAL	12-20-2024
Received:	<i>ZAYNE TENLEY</i>	<i>[Signature]</i>	YAL	11:20
Relinquished:				
Received:				
Relinquished:				
Received:				